

PLANT ITEM No. 24590-PTF-MV-TLP-VSL-00009A

Project:	RPP-WTP	P&ID:	24590-PTF-M6-TLP-P0001
Project No:	24590	Process Calculation:	Deleted /2
Project Site:	Hanford	Vessel Drawing	24590-PTF-MV-TLP-P0001
Description:	LAW SBS Condensate Re	ceipt Vessel	

Reference Data


Charge Vessels (Tag Numbers)	Not Applicable
Pulsejet Mixers / Agitators (Tag Numbers)	TLP-PJM-00001, TLP-PJM-00002, TLP-PJM-00003, TLP-PJM-00004, TLP-PJM-00005, TLP-PJM-00006, TLP-PJM-00007, TLP-PJM-00008
RFDs/Pumps (Tag Numbers)	Not Applicable

Design Data

Quality Level		CM	Fabrication Specs	24590-WTP-3F	PS-MV00-TP001	
Seismic Category SC-III		Design Code	ASME VIII Div 1			
Service/Contents		Radioactive Liquid	Code Stamp	Yes		
Design Specific Gravity		1.6	NB Registration	Yes		
Maximum Operating Volume	gal	114,060	Weights (lbs)	Empty	Operating	<u>Test</u>
Total Volume	gal	130,010	Estimated	218,400	1,769,100	1,303,300
	1		Actual *			

Inside Diameter	inch	312			Wind Design	Not	Required
Length/Height (TL-TL)	inch	328		Snow Design	Not Required		
		Vessel	Vessel	Coil/Jacket	Seismic Design	245	90-WTP-3PS-FB01-T0001
		Operating	<u>Design</u>	<u>Design</u>		245	90-WTP-3PS-MV00-TP002
Internal Pressure	psig	0	15	NIA	Seismic Base Moment *	ft*lb	
External Pressure	psig	0.22	8	N/A	Postweld Heat Treat	Not	Required ^
Temperature	°F	167	192	NIA	Corrosion Allowance	Inch	0.04 (Note 7 & 8) 2
Min. Design Metal Temp.	°F	40			Hydrostatic Test Pressure *	psig	

Note: Please note that source, special nuclear and byproduct materials, as defined in the Atomic Energy Act of 1954 (AEA), are regulated at the U.S. Department of Energy (DOE) facilities exclusively by DOE acting pursuant to its AEA authority. DOE asserts, that pursuant to the AEA, it has sole and exclusive responsibility and authority to regulate source, special nuclear, and byproduct materials at DOE-owned nuclear facilities. Information contained herein on radionuclides is provided for process description purposes only.



This Bound Document Contains a total of 5 Sheets.

			11	î .i	DA	INA
2	1/27/05	Issued for Permitting Use	111	Crould 5		NAKE
1	3/25/04	Issued for Permitting Use	Kathy Brightman	Chan Chung	Cliff Slater	Mall Hoffmann
0	12/18/02	Issued for Permitting Use	Jessica Jackson	Cliff Slater	N/A	Mark Hoffmann
REV	DATE	REASON FOR REVISION	PREPARER	CHECKER	REVIEWER	APPROVER

ISSUED BY RPP-WTP PDC

DATA SHEET #: 24590-PTF-MVD-TLP-P0001, Rev 2





PLANT ITEM No. 24590-PTF-MV-TLP-VSL-00009A

Materials of Construction

Component	<u>Material</u>	Minimum Thickness / Size	Containment
Top Head	UNS N08367	See Drawing	Auxiliary (See Note 1)
Shell	UNS N08367	See Drawing	Primary (See Note 1)
Bottom Head	UNS N08367	See Drawing	Primary (See Note 1)
Support (Skirt)	SA 240 304 with max. Carbon of 0.030 %	See Drawing	N/A
Jacket/Coils/Half-Pipe Jacket	NIA	NIA	N/A
Internals	UNS N08367	See Drawing	Thermowell Primary (See
			Note 1)
Pipe	UNS N08367 Seamless or N10276	See Drawing	See Note-1
Forgings/ Bar stock	UNS N08367	See Drawing	As Note-1 for Nozzle Necks
Gaskets	NIA	NIA	NIA
Bolting	NIA	NIA	N/A

Miscellaneous Data

Orientation	Vertical	Support Type	Skirt
Insulation Function	Not Applicable	Insulation Material	Not Applicable
Insulation Thickness (inch)	Not Applicable	Welds Surface Finish	De-scaled as laid

Remarks

* To be determined by the vendor.

Note 1: All welds forming part of the primary and auxiliary containment including nozzle attachment welds shall be subjected to 100% volumetric examination.

Note 2: Deleted

Note 3: Vessel volumes are approximate and do not account for manufacturing tolerances, nozzles, and displacement of internals

Note 4: Contents of this document are Dangerous Waste Permit affecting.

Note 5: This vessel is in a Black Cell.

Note 6: Deleted/2

Note 7: BNI shall ensure that an additional 0.056" is available for erosion in the bottom head and the Seller shall report the minimum thickness required for all specified loading conditions, exclusive of erosion and corrosion allowances. Note 8: BNI shall ensure that an additional 0.036" is available for erosion in the lower 4" of the interior conical surface of the pulse jet mixers. $\frac{1}{2}$

Note 9: All hydrodynamic loads are for BNI internal use only and are to be disregarded by the Seller.



PLANT ITEM No. 24590-PTF-MV-TLP-VSL-00009A

Equipment Cyclic Data Sheet

Plant Item Number	24590-PTF-TLP-VSL-00009A	3	
Component Description	Parent Vessel		

The information below is provisional and envelopes operational duty for fatigue assessment. It is not to be used as operational data.

Materials of Construction	UNS N08367
Design Life	40 years
Component Function and Life Cycle Description	This vessel receives intermittently LAW SBS condensate, off-spec effluent, and treated LAW concentrate. The vessel is emptied manually whenever it gets filled to the high level. Washdown is once per year.


Load Type		Min	Max	Number of Cycles	Comment
Design Pressure	psig	-8	15	10	Nominal assumption
Operating Pressure	psig	-0.22	0	5700	
Operating Temperature	°F	68	167	5700	Uniform material temperature range, not between two points
Contents Specific Gra	ıvity	1.0	1.6	2080	Nominal assumption
Contents Level	inch	28	358	5700	Coincident with pressure cycles
Localized Featur	res				
Nozzles		Within 50°F of temperature		As above	

Hydrodynamic Loading (Notes 6 & 9)/2

In normal operation, pulse jet mixers discharge liquid into the parent vessel imposing a cyclical hydrodynamic load on all internal components. Occasionally, an upset condition designated 'overblow' causes air to be discharged from any single pulse jet mixer. All internal components shall be designed for the combination of the normal operational hydrodynamic loads and overblow loads, and this load combination is also to be assumed to act concurrently with seismic loads.

The following table indicates the normal hydrodynamic pressure for at ranges of elevations in the vessel and the number of design cycles for each condition. The hydrodynamic forces cycle between the indicated pressure ranges applied across the projected area of the component. Positive hydrodynamic forces act in the radial, outward direction and the vertical, upward direction. Seller shall apply the radial load simultaneously in the radial direction and normal to the radial direction in the horizontal plane.


	Normal Operation Hydrodynamic Pressure Range, psi					Number of
Eleva	tion A	Eleva	tion B	Eleva	tion C	<u>Cycles</u>
Radial	Vertical	Radial	<u>Vertical</u>	Radial	Vertical	
-0.15 to 0.25	-0.15 to 0.15	-0.05 to 0.12	-0.15 to 0.15	-0.03 to 0.05	-0.06 to 0.15	3.7 X 10 ⁶





PLANT ITEM No. 24590-PTF-MV-TLP-VSL-00009A

Overblow loads vary as a function of the distance from the center of the overblowing pulse jet mixer nozzle and the elevation 'H' above the overblowing pulse jet mixer nozzle as plotted:



The overblow pressure shall only be applied to the projected area of the overblowing pulse jet mixer in the vertical, upward direction and to all surrounding components in the horizontal plane, radiating from the overblowing pulse jet mixer. Seller shall consider that any single pulse jet mixer may overblow 100 cycles.

Notes

 Cycle increase: The Seller must increase the numbers of operational cycles given above by 10% to account for commissioning duty unless otherwise noted.



PLANT ITEM No. 24590-PTF-MV-TLP-VSL-00009A

Equipment Cyclic Data Sheet

Plant Item Number	TLP-PJM-00001, TLP-PJM-00002, TLP-PJM-00003, TLP-PJM-00004, TLP-PJM-00005, TLP-PJM-00006, TLP-PJM-00007, TLP-PJM-00008
Component Description	Pulse Jet Mixers

The information below is provisional and envelopes operational duty for fatigue assessment. It is not to be used as operational data.

Materials of Construction	UNS N08367
Design Life	40 years
Component Function and Life Cycle Description	These pulse jet mixers are cyclically loaded using vacuum to fully fill the vessel with process liquid and compressed air to fully empty the vessel. The pulse jet mixers are contained within a parent vessel with varying liquid level. They shall be designed to cycle between the maximum design pressure and the minimum design pressure plus the external static head imposed by the parent vessel. The pulse jet mixer supports shall be designed to cycle between fully buoyant (pulse jet mixer empty and parent vessel full) and fully loaded (pulse jet mixer full and parent vessel empty) in addition to thrust.

Load Type		Max	Number of Cycles	Comment	
psig	FV	83	10	Nominal assumption	
psig	FV	58	3.7 X 10 ⁶		
°F	68	167	3.7 X 10 ⁶	3.7 X 10 ⁶ Pressure cycles to be at 167° F and non-coincident with temperature cycles. The range given is uniform material temperature range, not between adjacent points.	
Contents Specific Gravity		1.6	2080	Nominal assumption	
inch <i>Empty</i>		Flooded	3.7 X 10 ⁶	Coincident with pressure cycles	
es				- Alexandra	
Supports			As above with contents level changing coincident with pressure cycles.		
	psig °F	psig	psig FV 83 psig FV 58 °F 68 167 vity 1.0 1.6 inch Empty Flooded	psig FV 83 10 psig FV 58 3.7 X 10 ⁶ °F 68 167 3.7 X 10 ⁶ vity 1.0 1.6 2080 inch Empty Flooded 3.7 X 10 ⁶	

Notes

•	Cycle increase: The Seller must increase the numbers of operational cycles given above by	10% to account for commissioning duty
	unless otherwise noted.	